

DOCUMENT CODE  
CP558-DDM-A3064Rxxxx



**Master S.r.l., declares that:**

**KNOB "SPIN"**

**art. A3064.1**

**Passed the test of:**

**DURABILITY 200.000 CYCLE**

**On a test rig:**

**PNEUMATIC ACTUATOR**

**According to:**

**UNI EN 1906:2010**

**UNI EN 13126-1:2006**

**Building hardware - Lever handles and knob furniture - Requirements  
and test methods**

**Classification for handles:**

Category of use	Durability	Mass	Fire resistance	Safety in use	Corrosion resistance	Security	Type of operation
1	2	3	4	5	6	7	8
4	7	-	0	1	4	-	A

*Date of issue: 11/10/2018*